



Certificate of Compliance

Certificate: 2137671

Master Contract: 244391

Project: 80228282

Date Issued: 2025-02-27

Issued to: **Flow Management Devices, LLC.**
5225 S. 37th St. Suite 4
Phoenix, Arizona 85040
United States

Attention: Richard Palmer

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Dustin Pearce
Dustin Pearce

PRODUCTS

Class 3218 06 INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - For Hazardous Locations

Class 3218 86 INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus for Hazardous Locations-Certified to U.S. Standards

Class I, Division 1, Groups C and D;

Class I Division 2, Groups C and D

Maximum Operation Ambient 60°C

Small Volume Prover. Permanently connected, control/interface circuit 24Vdc, 500mA.

Model(s)
XXXXXX(XX)XXXX*XXXXXX

Models XXXXXX(XX)XXXX*XXXXXX, where X may be any alphanumeric character to designate mechanical options not affecting safety.